

PUBLIC WORKS DEPARTMENT (B & R), HARYANA



Office of the: Executive Engineer,
Provincial Division, PWD B&R Br., Faridabad.
Tele – 0129-2288187
Email ID: pwd-eepd1-faridabad@hry.nic.in

No.

8456

Dated 02/12/19

To

The Principal,
D.A.V Public School,
Sector-14, Faridabad.

Subject:- NOC for building structure safety certificate for (Main & Primary) D.A.V. Public School, Sector-14, Faridabad.

Reference: - Your office letter No.DAVPS-14/FBD/ADMN/2019-20/1097 dated 08.08.2019.

In the connection of above cited subject, it is submitted that the above said school building is inspected by Sh. Mohit Kumar, Junior Engineer of this office on 27.09.2019. The school building is constructed ground plus three floors. The inspection fee of site is deposited by the applicant vide GRN No.0056355429 dated 16.08.2019. Following are the features of the building observed during the inspection of the school:-

GROUND FLOOR:-

- At ground floor there are 08 no. Classrooms + 01 no. Reception lobby + 01 no. Principal office including Diving/Rest room + 08 no. Admin office + 01 Chemistry lab + 01 Physics lab + 01 no. Medical room + 01 no. Canteen + 01 no. Yogshala cum Multipurpose hall + 01 no. Record room + 01 Arya Samaj office + 01 no. Stationary room + 01 no. Music room + 01 no. Conference hall + 04 no. Staff room + 01 no. Store room + 02 no. toilet for boys + 02 no. toilet for girls + 05 no. staircases exist in the ground floor level.

FIRST FLOOR:-

- At first floor there are 17 no. Classrooms + 05 Staff room + 01 no. Supervisor office + 01 no. Art & Craft room + 01 no. Conference hall + 01 no. Biology lab + 01 no. Multimedia lab + 04 no. Computer room + 01 no. Music room + 01 no. Store room + 01 no. toilet for boys + 01 no. toilet for girls + 5 no. staircases exist in the first floor level.


SECOND FLOOR:-

- At second floor there are 18 no. Classrooms + 04 no. Staff room + 01 no. Chemistry lab + 02 no. Office + 01 no. Home Science lab + 02 no. Library + 01 no. Math lab + 02 no. toilet for boys + 02 no. toilet for girls + 04 no. staircases exist in the second floor level.

THIRD FLOOR:-

- At third floor there are 25 no. Classrooms + 04 no. Staff room + 02 no. Store room + 01 no. Art & Craft room + 01 no. Temporary lab in lobby area + 02 no. toilet for boys + 02 no. toilet for girls + 04 no. staircases exist in the third floor level.

CBranch 791


Principal
D.A.V. Public School
Sector-14,
FARIDABAD-121007

PUBLIC WORKS DEPARTMENT (B & R), HARYANA



Office of the: Executive Engineer,
Provincial Division, PWD B&R Br., Faridabad.
Tele – 0129-2288187
Email ID: pwd-eepd1-faridabad@hry.nic.in


No. _____

Dated _____

The building is having frame structure with R.C.C. columns, R.C.C. beams, R.C.C. slab & 9" thick brick wall on outer face wall. The structure stability certificate has been also enclosed, which issued by Lal & Associates, Office – L-143, Sector-51, Gurugram, Reference No.E/16/2019 dated 03.08.2019. The fire NOC has been issued by the Sr. Fire Station officers Faridabad Memo. No.DFS/FS/2016/421/68189 dated 21.09.2016 valid up to 20.09.2021. The hygiene certificate is submitted by the applicant on 28.11.2019 vide Deputy Civil Surgeon Faridabad letter No.SH/2019/182 dated 22.11.2019 valid upto 31.03.2020.

Keeping in view all the circumstances and the documents submitted by the applicant, the building is seems to be safe. The building safety certificate may be issued to the above mentioned school for the time period year. The periodical inspection of the school building must be ensured.

DA/Nil



Executive Engineer,
Provincial Division,
PWD B&R Br. Faridabad.

Endst No. _____

Dated _____

Copy of above is forwarded to the Sub Divisional Engineer, Provincial Sub Division No.3, PWD B&R BR., Faridabad for information and necessary action w.r.to his office memo no. 2361 dated 28.11.2019.

DA/Nil


Executive Engineer,
Provincial Division,
PWD B&R Branch, Faridabad


Principal
D.A.V. Public School
Sector-14,
FARIDABAD-121007