

ADFO/2022/E 105/356 Date-3-6-22

From Assistant Divisional Fire Officer/Fire Station Officer
Fire Station Sec 15A

To M/s DAV Public School
Sector 8 Faridabad

Memo No. 58/2022/363 dated : 03/06/2022

Subject: **Renewal of No Objection Certificate Under 15 mtrs. height from the fire Safety Point of View of the Group B-Educational Building at Sector 14 Faridabad of DAV Public School :**

Reference to you online No 030152223000583 dated 10/05/2022 on the subject cited above.

Tower Name	Floor Detail	Height	Ground Coverage
Educational Building	G+1st+2nd+3rd	14	27532.78 Sqft
Basement Level	Basement Area	Remarks	
no	no	no	

Your site for the Renewal of the Fire NOC has been inspected by the Team of Fire Station Officers, Fire Station Sec 15A from fire safety Point of View. The means of escape and Fire Protection system were checked and found as per the National Building Code of India, Part- IV guidelines.

In view of the satisfactory fire protection system / arrangement mentioned as above, this office has no objection for occupation from the Fire Safety point of view, with the following conditions:-

- 1) The owner/occupier shall keep duly trained Fire Staff in all three shifts.
- 2) The Fire Protection System tested during inspection shall be maintained properly & always should be in good working condition.
- 3) If any lapse is found in the fire protection system at the time of inspection or detected during outbreak of fire, action will be taken as per rules against you.
- 4) You are directed to apply for Renewal of NOC in future before 2 month of expiry of your NOC.
- 5) The open set back area is not checked at our end as it shall be checked by concerned building department.
- 6) The owner/occupier shall strictly follow the other applicable rules/ regulations/ byelaws laid down regarding fire safety system. If you fail to comply with any of the above terms & conditions you will be liable to be punished as per fire ordinance 2009 specially chapter- III Section 31 Sub-Section 1 & 2 of Fire Act 2009.
- 7) You have to perform quarterly Fire Drill in your building as per NBC with intimation to Fire Department and video graphy evidence to be kept as a record which shall be produced at the time of next Renewal; Officials/Residents/R.W.A. should be mentioned in the drill.
- 8) If the Infringements of Byelaws remains un-noticed the Authority reserves the right to amend the NOC as and when any such Infringements comes to notice after giving an opportunity of being heard and the Authority shall stand Indemnified against any claim on this account.

The above Renewal of NOC is valid for **One** year from the date of issue of this letter Applying renewal of the same well in time shall be the responsibility of owner/occupier.

Remarks:- ok



Assistant Divisional Fire
Officer
Fire Station Sec 15A

Exercising the power of Director Fire Services, Haryana

Satyan
Principal
D.A.V. Public School
Sector-14,
FARIDABAD-121007



Digitally signed by Satyavan
Date: 2022.06.03 17:46:04
+05:30
Reason: Digital Verification

To Save Life & Property is our motto

Sector-15 A : 2284444 - 101
N.I.T. : 2412666
Ballbagarh : 2309744
Sector-31 : 2275886

HARYANA FIRE & EMERGENCY SERVICES FARIDABAD

No Objection Certificate (Under 15 Mtr. Height)

Ref. No. F/SI 20171 F.1068/24

Dated : 10-01-2018

Certified that M/s. D.A.V. PUBLIC SCHOOL has made satisfactory
Sector-14 Faridabad

Fire Safety arrangements as per requirement, hence this office has No Objection towards running of this
Educational from Fire Safety Point of View, with the condition of keeping trained staff, fire fighting
system tested during inspection shall always be available in good working condition. During inspection,
any lapses & non-functioning of fire fighting system will be at the sole responsibility of the
owner/management. The above Certificate can be cancelled at any time. This certificate does not permit to
violate any laws of the land, building. NOC from pollution control board and permission from other
concerned authorities. The validity of this Certificate is Five Years from 10-01-2018 to 09-01-2023

before expiry of this period you have to get renewed this NOC from this Office.

Note : Terms & Condition on Back Side.

[Signature]
Sr. Fire Station Officer
Faridabad

[Signature]
Principal

Sector-14,
FARIDABAD-121007